



DEPARTMENT OF ENVIRONMENTAL QUALITY

KATHLEEN BABINEAUX BLANCO

GOVERNOR

MIKE D. McDANIEL, Ph.D.

SECRETARY

Certified Mail# _____

FILE NUMBER: LA0036421
AI NUMBER: 4842
PERMIT ACTIVITY: PER20050002

City of Baton Rouge and Parish of East Baton Rouge
Central Wastewater Treatment Plant
P. O. Box 1471
Baton Rouge, LA 70821

Attention: Mr. Peter T. Newkirk, P. E. Public Works Director

Subject: Revoke and Reissue Louisiana Pollutant Discharge Elimination System (LPDES) permit to discharge treated sanitary wastewater into the Mississippi River from a publicly owned treatment works serving central Baton Rouge and East Baton Rouge Parish.

Gentlemen:

The Department of Environmental Quality proposes to revoke the LPDES permit issued on July 28, 2003 to the City of Baton Rouge and Parish of East Baton Rouge and reissue an LPDES permit with the effluent limitations, monitoring requirements, and special conditions listed in the attached DRAFT PERMIT. Please note that this is a DRAFT PERMIT only and as such does not grant any authorization to discharge. Authorization to discharge will be granted only after all requirements described herein are satisfied and by the subsequent issuance of a FINAL PERMIT.

This Office will publish the enclosed public notice one time in the local newspaper of general circulation, and the Department of Environmental Quality Public Notice Mailing List. In accordance with LAC 33:IX.6521.A, the applicant shall receive and is responsible for paying the invoice(s) from the newspaper(s). LAC 33:IX.6521.A states, "...The costs of publication shall be borne by the applicant."

The invoice, fee rating sheets, and a copy of the fee regulations will be sent under a separate cover letter as applicable. A copy of the entire Louisiana Water Quality Regulations (Volume 14) may be obtained from the LDEQ Office of Environmental Assessment, Post Office Box 4314, Baton Rouge, Louisiana 70821-4314, (225) 219-0399.

ENVIRONMENTAL SERVICES

: PO BOX 4313, BATON ROUGE, LA 70821-4313

P:225-219-3181 F:225-219-3309

WWW.DEQ.LOUISIANA.GOV

City of Baton Rouge and Parish of East Baton Rouge
RE: LA0036421/AI4842/PER20050002
Page Two

Pursuant to LAC 33:IX.1309.I, LAC 33:IX.6509.A.1 and LAC 33:IX.1.1701, you must pay any outstanding fees to the Department. Therefore, you are encouraged to verify your facility's fee status by contacting LDEQ's Office of Management and Finance, Financial Services Division (225) 219-3863. Failure to pay in the manner and time prescribed could result in applicable enforcement actions as prescribed in the Environmental Quality Act, including, but not limited to revocation or suspension of the applicable permit, and/or assessment of a civil penalty against you.

A Municipal Water Pollution Prevention Environmental Audit Report Form will be furnished upon finalization of the permit. Please consult Part II, Section B of the permit for instructions regarding this audit.

For sanitary treatment plants, the plans and specifications must be approved by the Department of Health and Hospitals, Office of Public Health, P. O. Box 4489, Baton Rouge, Louisiana 70821-4489, telephone (225) 219-5044.

Should you have any questions concerning any part of the DRAFT PERMIT, public notice requirements, or fees, please contact Ms. Paula M. Roberts, Office of Environmental Services, at the address on the preceding page or telephone (225) 219-3086. Please reference your Agency Interest Number, AI 4842, and your Louisiana Pollutant Discharge Elimination System Number, LA0036421, on all future correspondence to the Department.

Sincerely,



Tom Killeen, Environmental Scientist Manager
Municipal and General Water Permits Unit

pmr

Attachments: draft permit, dated public notice, factsheet, and feesheet:

cc: IO-W

Paula M. Roberts, ESIII
Water Permits Division

ec: Mr. Walter Jenkins, WWT Plant Manager
Central Wastewater Treatment Plant
wjenkins@brgov.com

Mr. Mitch O'Brien, WW Lab Supervisor
Central Wastewater Treatment Plant
mobrien@brgov.com

Public Health Chief Engineer
Department of Health and Hospitals
OPH-Center for Environmental Health Services

Supervisor, Louisiana Field Office
US Fish and Wildlife Services

Ms. Gayle Denino
Office of Management and Finance

Permit Compliance Unit
Office of Environmental Compliance

Ronnie Bean, ESC
Municipal and General Water Permits Unit

Public Notice Scheduled for Publication

The notice associated with the following:

**PUBLIC NOTICE FOR EXTENSION OF PUBLIC COMMENT
ON A DRAFT WATER DISCHARGE PERMIT
CITY OF BATON ROUGE AND PARISH OF EAST BATON ROUGE
CENTRAL WASTEWATER TREATMENT PLANT
EAST BATON ROUGE PARISH, LOUISIANA
LA 0036421 / AI 4842 / PER20050002**

is scheduled to publish in the following paper (s)

Newspaper(s)	Scheduled Publication Date*
The Advocate	Friday, April 27, 2007

In accordance with **LAC 33:IX.6521.A**, the applicant is responsible for payment of all costs of publication. Newspaper will bill applicant directly. Questions regarding publication or payment may be directed to:

DEQ Office of Environmental Services, Public Participation Group Staff:

Name: Barbara Mason

Phone: (225) 219-3280

Email: barbara.mason@la.gov

Comments:

*Actual date of publication is pending confirmation of publication by newspaper(s)

PUBLIC NOTICE
LOUISIANA DEPARTMENT OF ENVIRONMENTAL QUALITY (LDEQ)
CITY OF BATON ROUGE AND PARISH OF EAST BATON ROUGE
CENTRAL WASTEWATER TREATMENT PLANT
DRAFT WATER DISCHARGE PERMIT

The LDEQ, Office of Environmental Services, is accepting written comments on a draft Louisiana Pollutant Discharge Elimination System (LPDES) permit prepared for the City of Baton Rouge and Parish of East Baton Rouge, Central Wastewater Treatment Plant, P. O. Box 1471, Baton Rouge, LA 70821. **The facility is located at 2443 River Road, Baton Rouge, East Baton Rouge Parish**

The principal discharge from this existing source is made into the Mississippi River, waters of the state classified for primary contact recreation, secondary contact recreation and propagation of fish and wildlife and drinking water supply. Under the SIC Code 4952, the applicant proposes to discharge treated sanitary wastewater from a publicly owned treatment works serving central Baton Rouge and East Baton Rouge Parish.

During the preparation of this permit, it has been determined that the discharge will have no adverse impact on the existing uses of the receiving waterbody. As with any discharge, however, some change in existing water quality may occur.

Written comments, written requests for a public hearing or written requests for notification of the final decision regarding this permit action may be submitted to Ms. Soumaya Ghosn at LDEQ, Public Participation Group, P.O. Box 4313, Baton Rouge, LA 70821-4313. **Written comments and/or written requests must be received by 12:30 p.m., Wednesday, May 30, 2007.** Written comments will be considered prior to a final permit decision.

If LDEQ finds a significant degree of public interest, a public hearing will be held. LDEQ will send notification of the final permit decision to the applicant and to each person who has submitted written comments or a written request for notification of the final decision.

The draft permit, application and fact sheet are available for review at the LDEQ, Public Records Center, Room 127, 602 North 5th Street, Baton Rouge, LA. Viewing hours are from 8:00 a.m. to 4:30 p.m., Monday through Friday (except holidays). **The available information can also be accessed electronically on the Electronic Document Management System (EDMS) on the DEQ public website at www.deq.louisiana.gov.**

Inquiries or requests for additional information regarding this permit action should be directed to Paula M. Roberts, LDEQ, Water Permits Division, P.O. Box 4313, Baton Rouge, LA 70821-4313, phone (225) 219-3086.

Persons wishing to be included on the LDEQ permit public notice mailing list or for other public participation related questions should contact the Public Participation Group in writing at LDEQ, P.O. Box 4313, Baton Rouge, LA 70821-4313, by email at maillistrequest@ldeq.org or contact the LDEQ Customer Service Center at (225) 219-LDEQ (219-5337).

Permit public notices including electronic access to the draft permit and fact sheet can be viewed at the LDEQ permits public notice webpage at www.deq.louisiana.gov/apps/pubNotice/default.asp and general information related to the public participation in permitting activities can be viewed at www.deq.louisiana.gov/portal/tabid/2198/Default.aspx.

Alternatively, individuals may elect to receive the permit public notices via email by subscribing to the LDEQ permits public notice List Server at http://www.doa.louisiana.gov/oes/listservpage/ldeq_pn_listserv.htm

All correspondence should specify AI Number 4842, Permit Number LA0036421, and Activity Number PER20050002.

Publication date: April 27, 2007

DRAFT

LPDES PERMIT
NUMBER: LA036421
AGENCY INTEREST
NUMBER: AI 4842
PER20050002



OFFICE OF ENVIRONMENTAL SERVICES
Water Discharge Permit

Pursuant to the Clean Water Act, as amended (33 U.S.C. 1251 et seq.), and the Louisiana Environmental Quality Act, as amended (La. R. S. 30:2001 et seq.), rules and regulations effective or promulgated under the authority of said Acts, and in reliance on statements and representations heretofore made in the application, a Louisiana Pollutant Discharge Elimination System permit is issued authorizing

City of Baton Rouge and Parish of East Baton Rouge
Central Wastewater Treatment Plant
P. O. Box 1471
Baton Rouge, LA 70821

Type Facility: publicly owned treatment works
Location: 2443 River Road, East Baton Rouge Parish
Receiving Waters: Mississippi River (070301)

to discharge in accordance with effluent limitations, monitoring requirements, and other conditions set forth in Parts I, II, and III attached hereto.

This permit shall become effective on

This permit and the authorization to discharge shall expire five (5) years from the effective date of the permit.

Issued on

DRAFT

Chuck Carr Brown, Ph. D.
Assistant Secretary

DRAFT

FINAL EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

During the period beginning the effective date of the permit and lasting through the expiration date of the permit the permittee is authorized to discharge from:

Outfall 001, treated sanitary wastewater (**design flow** is 31.6 MGD) located at the geographical coordinates of Latitude 30° 25' 18" North and Longitude 91° 11' 43" West.

Such discharges shall be limited and monitored by the permittee as specified below:

<u>Effluent Characteristic</u>		<u>Discharge Limitations</u>			<u>Monitoring Requirements</u>	
	Storet	(lbs/day)	other units (specify)		Measurement	Sample
	<u>Code</u>	<u>Avg.</u>	<u>Avg.</u>	<u>Avg.</u>	<u>Frequency</u>	<u>Type</u>
Flow-MGD	50050	---	Report	Report	Continuous	Recorder ‡
BOD ₅	00310	7906	30 mg/l	45 mg/l	1/day	24-Hr Comp
TSS	00530	7906	30 mg/l	45 mg/l	1/day	24-Hr Comp
Total Residual Chlorine (TRC)†	50060	---	0.78 mg/l	---	1/day	Grab
Fecal Coliform colonies/100ml	74055	---	200	400	1/day	Grab
pH (Standard Units)*	00400	---	---	---	1/day	Grab
Toxic Substances ^{3/}	51168	---	---	---	1/6 months	24-Hr Comp

QUALITY (PERCENT % UNLESS STATED)

	Storet	<u>Monthly Avg. Min</u>	<u>48-Hour Min.</u>	<u>Measurement Frequency ^{2/}</u>	<u>Sample Type</u>
	<u>Code</u>				
Biomonitoring ^{4/}					
<u>Daphnia pulex</u>	TEM3D ^{1/}	Report	Report	1/quarter	24-hour Composite
	TOM3D	Report	Report	1/quarter	24-hour Composite
	TQM3D	Report	Report	1/quarter	24-hour Composite
<u>Pimephales promelas</u>	TEM6C ^{1/}	Report	Report	1/quarter	24-hour Composite
	TOM6C	Report	Report	1/quarter	24-hour Composite
	TQM6C	Report	Report	1/quarter	24-hour Composite

If a test failure has occurred and the required retests have been performed, the test results are to be reported on the DMR as follows:

Whole Effluent Toxicity Testing ☐☐

	Storet	Monthly Avg.	7-Day	Measurement	Sample
	<u>Code</u>	<u>Minimum</u>	<u>Minimum</u>	<u>Frequency ^{2/}</u>	<u>Type</u>
Retest #1	22415	Report ^{1/}	Report ^{1/}	As Required	24-Hr. Composite
Retest #2	22416	Report ^{1/}	Report ^{1/}	As Required	24-Hr. Composite

FINAL EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

- ^{1/} Species Quality Reporting Units: Pass = 0, Fail = 1
- ^{2/} Monthly Testing Required only if routine test for reporting period (for either species).
- † If chlorination is used to achieve the limitation on Fecal Coliform Bacteria, the effluent shall contain no more than 0.78 mg/l Total Residual Chlorine (TRC) after dechlorination and prior to final disposal at any one time monitored by grab sample.
 - ^{3/} See Part II, Section D, Toxic Substances.
 - ^{4/} See Part II, Section F, Whole Effluent Toxicity Testing Requirements.
 - ‡ Includes totalizing meter or totalizer.
 - * The pH shall not be less than 6.0 standard units nor greater than 9.0 standard units. The permittee shall report on the Discharge Monitoring Reports both the minimum and maximum instantaneous pH values measured.

There shall be no discharge of floating solids or visible foam in other than trace amounts.

Samples taken in compliance with the monitoring requirements specified above shall be taken at the following location:

Outfall 001, at the point of discharge from the last treatment unit prior to mixing with other waters.

FINAL EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

During the period beginning the effective date of the permit and lasting through the expiration date of the permit the permittee is authorized to discharge from:

Outfall 002, treated sanitary wastewater (**design flow** is 31.6 MGD) located at the geographical coordinates of Latitude 30° 25' 25" North and Longitude 91° 11' 41" West. **(NOTE: This outfall will be used intermittently, during periods of high water in the Mississippi River, or at times of repair and rehab to the primary outfall pipe, otherwise, there will be no discharge.)**

Such discharges shall be limited and monitored by the permittee as specified below:

<u>Effluent Characteristic</u>		<u>Discharge Limitations</u>			<u>Monitoring Requirements</u>	
	Storet Code	(lbs/day) Monthly Avg.	other units (specify) Monthly Avg.	Weekly Avg.	Measurement Frequency	Sample Type
Flow-MGD	50050	---	Report	Report	Continuous	Recorder ‡
BOD ₅	00310	7906	30 mg/l	45 mg/l	1/day	24-Hr Comp
TSS	00530	7906	30 mg/l	45 mg/l	1/day	24-Hr Comp
Total Residual Chlorine (TRC)†	50060	---	0.78 mg/l	---	1/day	Grab
Fecal Coliform colonies/100ml	74055	---	200	400	1/day	Grab
pH (Standard Units)*	00400	---	---	---	1/day	Grab
Toxic Substances ^{3/}	51168	---	---	---	1/6 months	24-Hr Comp

QUALITY (PERCENT % UNLESS STATED)

	Storet Code	Monthly Avg. Min	48-Hour Min.	Measurement Frequency ^{2/}	Sample Type
Biomonitoring ^{4/}					
<u>Daphnia pulex</u>	TEM3D ^{1/}	Report	Report	1/quarter	24-hour Composite
	TOM3D	Report	Report	1/quarter	24-hour Composite
	TQM3D	Report	Report	1/quarter	24-hour Composite
<u>Pimephales promelas</u>	TEM6C ^{1/}	Report	Report	1/quarter	24-hour Composite
	TOM6C	Report	Report	1/quarter	24-hour Composite
	TQM6C	Report	Report	1/quarter	24-hour Composite

If a test failure has occurred and the required retests have been performed, the test results are to be reported on the DMR as follows:

Whole Effluent Toxicity Testing ☐☐

	Storet Code	Monthly Avg. Minimum	7-Day Minimum	Measurement Frequency ^{2/}	Sample Type
Retest #1	22415	Report ^{1/}	Report ^{1/}	As Required	24-Hr. Composite
Retest #2	22416	Report ^{1/}	Report ^{1/}	As Required	24-Hr. Composite

FINAL EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

- ^{1/} Species Quality Reporting Units: Pass = 0, Fail = 1
- ^{2/} Monthly Testing Required only if routine test for reporting period (for either species).
- † If chlorination is used to achieve the limitation on Fecal Coliform Bacteria, the effluent shall contain no more than 0.78mg/l Total Residual Chlorine (TRC) after dechlorination and prior to final disposal at any one time monitored by grab sample.
- ^{3/} See Part II, Section D, Toxic Substances.
- ^{4/} See Part II, Section F, Whole Effluent Toxicity Testing Requirements.
- ‡ Includes totalizing meter or totalizer.
- * The pH shall not be less than 6.0 standard units nor greater than 9.0 standard units. The permittee shall report on the Discharge Monitoring Reports both the minimum and maximum instantaneous pH values measured.

There shall be no discharge of floating solids or visible foam in other than trace amounts.

Samples taken in compliance with the monitoring requirements specified above shall be taken at the following location:

Outfall 002, at the point of discharge from the last treatment unit prior to mixing with other waters.

PART II

OTHER REQUIREMENTS

In addition to the standard conditions required in all permits and listed in Part III, the office has established the following additional requirements in accordance with the Louisiana Water Quality Regulations.

SECTION A. GENERAL STATEMENTS

1. The Department of Environmental Quality reserves the right to impose more stringent discharge limitations or additional restrictions, if necessary, to maintain the water quality integrity and the designated uses of the receiving water bodies.
2. This permit does not in any way authorize the permittee to discharge a pollutant not listed or quantified in the application or limited or monitored for in the permit.
3. Authorization to discharge pursuant to the conditions of this permit does not relieve the permittee of any liability for damages to state waters or private property. For discharges to private land, this permit does not relieve the permittee from obtaining proper approval from the landowner for appropriate easements and rights of way.
4. For definitions of monitoring and sampling terminology see Part III, Section F.
5. In the event that an unauthorized discharge into the Mississippi River or any other water of the state used for potable water supply within the State of Louisiana; from a permitted or unpermitted, licensed or unlicensed treatment works, operating facility, wharf, onshore riverside site, transport vehicle, or vessel; could reasonably be expected to interfere with or significantly impact downstream potable or industrial water usage, the discharger shall notify the Department immediately, but in no case later than one (1) hour after learning of the discharge, by telephone or other rapid communication means, in accordance with the notification procedures in Part III of this permit.

In the event that an unauthorized discharge is made into the Mississippi River, the discharger shall notify the Lower Mississippi River Waterworks Warning Network immediately by telephone or other rapid communication means.

6. 24-hour Oral Reporting: Daily Maximum Limitation Violations

Under the provisions of Part III Section D.6.b.3 of this permit, violations of daily maximum limitations for the following pollutants shall be reported orally to the Office of Environmental Compliance within 24 hours from the time the permittee became aware of the violation followed by a written report in five days.

Pollutants: None

In addition, enforcement authority has been retained by EPA. Therefore, EPA must also be notified according to the provisions above until notification that enforcement authority has been assumed by LDEQ. The written report shall be submitted to the following address:

OTHER REQUIREMENTS (continued)

U.S. Environmental Protection Agency, Region 6
Water Enforcement Branch, 6 EN-WC
1445 Ross Ave.
Dallas, Texas 75202

7. As an exception to Part III Section D.6.e.(1), the permittee shall report all overflows in the distribution system with the Discharge Monitoring Report submittal. These reports shall be summarized and reported in tabular format. The summaries shall include: the date, time, duration, location, estimated volume, and cause of the overflow; observed environmental impacts from the overflow; actions taken to address the overflow; and the ultimate discharge location if not contained (e.g., storm sewer system, ditch, tributary). All other overflows and overflows which endanger human health or the environment must be reported in the manner described in Part III, Section D.6 of the permit.
8. PERCENT REMOVAL: The 85% removal requirement is based upon LAC 33:IX.5905.A.3. and B.3. which describes the minimum level of effluent quality attainable by secondary treatment. The Influent Characteristics and the Monthly Average Percent Removal requirements have been removed from Part I (Effluent Limitations) of this permit. Even though the 85% removal has been removed from Part I, it remains a requirement of this LPDES permit (see Part III – Standard Conditions for LPDES Permits). While the Consent Decree is in effect any penalty assessment of the violation of 85% removal shall be in accordance with the Consent Decree entered on 3/14/01 in the matter entitled “United States of America and State of Louisiana vs. City of Baton Rouge and Parish of East Baton Rouge “Civil Action #01-978-B-M3, Section XVI. Interim Effluent Limits.
9. In accordance with La.R.S.40:1149, it shall be unlawful for any person, firm, or corporation, both municipal and private, operating a water supply system or sewerage system to operate same unless the competency of the operator is duly certified to by the State Health Officer. Furthermore, it shall be unlawful for any person to perform the duties of an operator without being duly certified. Therefore, the City of Baton Rouge and Parish of East Baton Rouge should take whatever action is necessary to comply with La.R.S. 40:1149.
10. REOPENER CLAUSE: Please be aware that the Department will be conducting a TMDL in the Mississippi River Basin scheduled for completion on March 31, 2010. The Department of Environmental Quality reserves the right to reopen this permit to impose more stringent discharge limitations and/or additional restrictions as a result of the TMDL. Therefore, prior to upgrading or expanding this facility, the permittee should contact the Department to determine the status of the work being done to establish future effluent limitations and additional permit conditions.
11. The permittee shall achieve compliance with the effluent limitations and monitoring requirements specified for discharges in accordance with the following schedule:

EFFECTIVE DATE OF THE PERMIT

OTHER REQUIREMENTS (continued)

12. Monitoring results must be reported on a Discharge Monitoring Report (DMR) form (EPA No. 3320-1 or an approved substitute). All monitoring reports must be retained for a period of at least three (3) years from the date of the sample measurement. The permittee shall make available to this Department, upon request, copies of all monitoring data required by this permit.

If there is a no discharge event at any of the monitored outfall(s) during the sampling period, place an "X" in the NO DISCHARGE box located in the upper right corner of the Discharge Monitoring Report.

Reporting periods shall end on the last day of the month. Monitoring results for each month shall be summarized on a Discharge Monitoring Report (DMR) Form and submitted to this Department per the schedule below, postmarked no later than the 15th day of the month following each reporting period.

Permittees shall be required to submit DMRs according to the following schedule or as established in the permit:

For parameter(s) with monitoring frequency(ies) of 1/month or more frequent:

Submit DMR by the 15th day of the following month.

For parameter(s) with monitoring frequency(ies) of 1/quarter:

<u>Monitoring Period</u>	<u>DMR Due Date</u>
January 1-March 31	April 15 th
April 1- June 30	July 15 th
July 1 – September 30	October 15 th
October 1- December 31	January 15 th

For parameter(s) with monitoring frequency(ies) of semi-annual:

<u>Monitoring Period</u>	<u>DMR Due Date</u>
January 1-June 30	July 15 th
July 1- December 31	January 15 th

For parameter(s) with monitoring frequency(ies) of 1/year:

<u>Monitoring Period</u>	<u>DMR Due Date</u>
January 1-December 31	January 15 th

OTHER REQUIREMENTS (continued)

Duplicate copies of DMRs (one set of originals and one set of copies) signed and certified as required by LAC 33:IX.2503.B, and all other reports (one set of originals) required by this permit shall be submitted to the Permits Compliance Unit at the following address:

Department of Environmental Quality
Office of Environmental Compliance
Enforcement Division
Post Office Box 4312
Baton Rouge, Louisiana 70821-4312
Attention: Permit Compliance Unit

In addition, enforcement authority has been retained by EPA. Therefore, the original and a copy of the DMRs must also be submitted to the following address until notification that enforcement authority has been assumed by LDEQ:

U.S. Environmental Protection Agency, Region 6
Water Enforcement Branch, 6 EN-WC
1445 Ross Ave.
Dallas, Texas 75202

OTHER REQUIREMENTS (continued)

SECTION B. MUNICIPAL WATER POLLUTION PREVENTION

Pollution Prevention Requirements

1. The permittee shall institute or continue programs directed towards pollution prevention. The permittee shall institute or continue programs to improve the operating efficiency and extend the useful life of the facility. The permittee will complete an annual Environmental Audit Report **each year** for the life of this permit according to the schedule below. A copy of the Environmental Audit Form has been attached to this permit. Please make additional copies to be utilized for each year of this permit. Additional copies can be obtained upon request.

The audit evaluation period is as follows:

Audit Period Begins	Audit Period Ends	Audit Report Completion Date
Effective Date of Permit	12 Months from Audit Period Beginning Date	3 Months from Audit Period Ending Date

These reports shall discuss the following items:

- a. The influent loading, flow, and design capacity of the facility;
- b. The effluent quality and plant performance;
- c. The age of the wastewater treatment facility;
- d. Bypasses and overflows of the tributary sewerage system and treatment works;
- e. The ultimate disposition of the sewage sludge;
- f. Landfilling of sewage sludge and potential alternatives (if applicable);
- g. New developments at the facility;
- h. Operator certification and training;
- i. The financial status of the facility; and
- j. A subjective evaluation of conditions at the facility.

OTHER REQUIREMENTS (continued)

2. A resolution from the permittee's governing body shall be obtained as part of the Environmental Audit Report. This resolution shall include, at a minimum, the following:
 - a. An acknowledgement that the governing body has reviewed the Environmental Audit Report;
 - b. A description of actions that the permittee will take to maintain compliance with the permit conditions, and if necessary, include a schedule outlining major projects to be accomplished.
3. The Environmental Audit Report and the governing body's resolution must be signed by a duly authorized representative of the permittee and shall be maintained with the permit and permit related records (i.e. lab data, DMRs), and made available upon request by duly authorized regional inspectors and/or DEQ Headquarters representatives.

OTHER REQUIREMENTS (continued)

SECTION C. CONTRIBUTING INDUSTRIES AND PRETREATMENT REQUIREMENTS

1. The permittee shall operate an industrial pretreatment program in accordance with Section 402(b)(8) of the Clean Water Act, the General Pretreatment Regulations (LAC 33:IX.Chapter 61) and the approved POTW pretreatment program submitted by the permittee. The pretreatment program was approved on August 22, 1984 and modified October 9, 1992. Pretreatment Program elements are developed and tracked under LA0036412. In specific reference to Technically Based Local Limits (TBLL) certification/re-assessment, please refer to Section C.2., paragraph 2 of the aforementioned permit. The Sewer Use Ordinance and the Pretreatment Program have not been modified to come into compliance with LAC 33:IX Subpart 2.Chapter 61. The Permittee shall submit all necessary proposed modifications to the Louisiana Department of Environmental Quality, Office of Environmental Services within 6 months of the effective date of this permit. The POTW pretreatment program is hereby incorporated by reference and shall be implemented in a manner consistent with the following requirements:
 - a. Industrial user information shall be updated at a frequency adequate to ensure that all IUs are properly characterized at all times;
 - b. The frequency and nature of industrial user compliance monitoring activities by the permittee shall be commensurate with the character, consistency and volume of waste. However, in keeping with the requirements of LAC 33:IX.6115.F.2.e, the permittee must inspect and sample the effluent from each Significant Industrial User at least once a year. This is in addition to any industrial self-monitoring activities;
 - c. The permittee shall enforce and obtain remedies for noncompliance by any industrial users with applicable Pretreatment Standards and Requirements;
 - d. The permittee shall control through permit, order, or similar means, the contribution to the POTW by each Industrial User to ensure compliance with applicable Pretreatment Standards and Requirements. In the case of Industrial Users identified as significant under LAC 33:IX.6105, this control shall be achieved through individual or general control mechanisms, in accordance with LAC 33:IX.6115.F.1.c. Both individual and general control mechanisms must be enforceable and contain, at a minimum, the following conditions:
 - (1) Statement of duration (in no case more than five years);
 - (2) Statement of non-transferability without, at a minimum, prior notification to the POTW and provision of a copy of the existing control mechanism to the new owner or operator;
 - (3) Effluent limits, including Best Management Practices, based on applicable general Pretreatment Standards, categorical Pretreatment Standards, local limits, and State and local law;
 - (4) Self-monitoring, sampling, reporting, notification and recordkeeping requirements, including an identification of the pollutants to be monitored, (If applicable, include the process for seeking a waiver for a pollutant neither present nor expected to be present in the Discharge in accordance with LAC 33:IX.6123.E.2. Any grant of the monitoring waiver by control authority

OTHER REQUIREMENTS (continued)

- must be included as a condition in the user's control mechanism in accordance with LAC 33:IX.6123.E.2.d.), sampling location, sampling frequency, and sample type, based on the applicable general Pretreatment Standards in LAC 33:IX, Chapter 61, categorical Pretreatment Standards, local limits, and State and local law; and
- (5) Statement of applicable civil and criminal penalties for violation of Pretreatment Standards and Requirements, and any applicable compliance schedule. Such schedules may not extend the compliance date beyond federal deadlines; and
 - (6) Requirements to control slug discharges, if determined by the POTW to be necessary.
- e. The permittee shall evaluate whether each Significant Industrial User needs a plan or other action to control slug discharges, in accordance with LAC 33:IX.6115.F.2.f.;
 - f. The permittee shall provide adequate staff, equipment, and support capabilities to carry out all elements of the pretreatment program; and,
 - g. The approved program shall not be modified by the permittee without the prior approval of the Louisiana Department of Environmental Quality.
2. The permittee shall establish and enforce specific limits to implement the provisions of LAC 33:IX.6109.A and B, as required by LAC 33:IX.6109.C. POTWs may develop Best Management Practices (BMPs) to implement paragraphs 6109.C.1 and C.2. Such BMPs shall be considered local limits and Pretreatment Standards. Each POTW with an approved pretreatment program shall continue to develop these limits as necessary and effectively enforce such limits.

The permittee shall, within sixty (60) days of the effective date of this permit, (1) submit a **WRITTEN CERTIFICATION** that a technical evaluation has demonstrated that the existing technically based local limits (TBLL) are based on current state water quality standards and are adequate to prevent pass through of pollutants, inhibition of or interference with the treatment facility, worker health and safety problems, and sludge contamination, **OR** (2) submit a **WRITTEN NOTIFICATION** that a technical evaluation revising the current TBLL and a draft sewer use ordinance which incorporates such revisions will be submitted within 12 months of the effective date of this permit.

Upon approval by the Water Division Director, all specific prohibitions or limits developed under this requirement are deemed to be conditions of this permit. The specific prohibitions set out in LAC 33:IX.6109.B shall be enforced by the permittee unless modified under this provision.

3. The permittee shall analyze the treatment facility influent and effluent for the presence of the toxic pollutants listed in LAC 33:IX.7107 Appendix D (NPDES Application Testing Requirements) Table II at least once/six months and the toxic pollutants in Table III at least once/six months. If, based upon information available to the permittee, there is reason to

OTHER REQUIREMENTS (continued)

suspect the presence of any toxic or hazardous pollutant listed in Table V, or any other pollutant, known or suspected to adversely affect treatment plant operation, receiving water quality, or solids disposal procedures, analysis for those pollutants shall be performed at least once/three months on both the influent and the effluent.

The influent and effluent samples collected shall be composite samples consisting of at least 12 aliquots collected at approximately equal intervals over a representative 24 hour period and composited according to flow. Sampling and analytical procedures shall be in accordance with guidelines established in 40 CFR 136. The effluent samples shall be analyzed to a level as required in (6) below. Where composite samples are inappropriate, due to sampling, holding time, or analytical constraints, at least 4 grab samples, taken at equal intervals over a representative 24 hour period, shall be taken.

4. The permittee shall prepare annually a list of Industrial Users which during the preceding twelve months were in significant noncompliance with applicable pretreatment requirements. For the purposes of this Part, significant noncompliance shall be determined based upon the more stringent of either criteria established at LAC 33:IX.6115.F.2.h [rev. 10/14/05] or criteria established in the approved POTW pretreatment program. This list is to be published annually in newspaper of general circulation that provides meaningful public notice within the jurisdiction(s) served by the POTW during the month of August.

In addition, during the month of August the permittee shall submit an updated pretreatment program status report to the Louisiana Department of Environmental Quality, Office of Environmental Services containing the following information:

- a. An updated list of all significant industrial users and identify (if applicable) any Industrial Users that the Control Authority has chosen to classify as Non-Significant Categorical Industrial Users (NSCIUs) (defined in LAC 33:IX.6105.Significant Industrial User.b) and/or Middle Tier CIUs (defined in LAC 33:IX.6123.E.3.a-c). This list must also identify:
 - (1) Industrial Users subject to categorical Pretreatment Standards that are determined by the Control Authority to be eligible and approved for reduced monitoring and reporting requirements under LAC 33:IX.6123.E.2 and 3;
 - (2) Industrial Users subject to the following categorical Pretreatment Standards: Organic Chemicals, Plastics, and Synthetic Fibers (OCPSF) (40 CFR Part 414), Petroleum Refining (40 CFR Part 419), and Pesticide Chemicals (40 CFR Part 455) for which the Control Authority has chosen to use concentration-based standards (as allowed in LAC 33:IX.6111.C.6) in lieu of categorical flow-based mass standards;
 - (3) Categorical Industrial Users subject to concentration-based standards for which the Control Authority has chosen to convert the concentration-based standards to equivalent mass limits, as allowed at LAC 33:IX.6111.C.5.

OTHER REQUIREMENTS (continued)

- (4) General Control Mechanisms used for similar groups of SIUs along with the substantially similar types of operations and the types of wastes that are the same, for each separate General Control Mechanism, as allowed at LAC 33:IX.6115.F.1.c; and
 - (5) Best Management Practices or Pollution Prevention alternatives required by a categorical Pretreatment Standard or as a local limit requirement that are *implemented and documentation to demonstrate compliance, as required at LAC 33:IX.6123.B, E, and H.*
- b. For each industrial user listed the following information shall be included:
- (1) Standard Industrial Classification (SIC) or (NAISC) code and categorical determination;
 - (2) Control document status. Whether the user has an effective control document, and the date such document was last issued, reissued, or modified, (indicate which industrial users were added to the system (or newly identified) within the previous 12 months);
 - (3) A summary of all monitoring activities performed within the previous 12 months. The following information shall be reported:
 - * total number of inspections performed;
 - * total number of sampling visits made;
 - (4) Status of compliance with both effluent limitations and reporting requirements. Compliance status shall be defined as follows:
 - * Compliant (C) - no violations during the previous 12 month period;
 - * Non-compliant (NC) - one or more violations during the previous 12 months but does not meet the criteria for significantly noncompliant industrial users;
 - * Significant Noncompliance (SN) - in accordance with requirements described in d. above; and
 - (5) For significantly noncompliant industrial users, indicate the nature of the violations, the type and number of actions taken (notice of violation, administrative order, criminal or civil suit, fines or penalties collected, etc.) and current compliance status. If ANY industrial user was on a schedule to attain compliance with effluent limits, indicate the date the schedule was issued and the date compliance is to be attained.

OTHER REQUIREMENTS (continued)

- b. A list of all significant industrial users whose authorization to discharge was terminated or revoked during the preceding 12 month period and the reason for termination.
- c. A report on any interference, pass through, upset or POTW permit violations known or suspected to be caused by industrial contributors and actions taken by the permittee in response.
- d. The results of all influent and effluent analyses performed pursuant to Part II(C)(3) above.
- e. A copy of the newspaper publication of the significantly noncompliant industrial users giving the name of the newspaper and the date published, and
- f. The information requested may be submitted in tabular form as per the example tables provided for your convenience.
- g. The monthly average water quality based effluent concentration necessary to meet the state water quality standards as developed in the approved technically based local limits.

In addition, enforcement authority has been retained by EPA. Therefore, a copy of the pretreatment program status report must also be submitted to the following address:

U.S. Environmental Protection Agency, Region 6
Water Enforcement Branch, 6 EN-WC
1445 Ross Ave.
Dallas, Texas 75202

- 5. The permittee shall provide adequate notice of the following:
 - a. Any new introduction of pollutants into the treatment works from an indirect discharger which would be subject to Sections 301 and 306 of the Act if it were directly discharging those pollutants; and
 - b. Any substantial change in the volume or character of pollutants being introduced into the treatment works by a source introducing pollutants into the treatment works at the time of issuance of the permit.

Adequate notice shall include information on (i) the quality and quantity of effluent to be introduced into the treatment works, and (ii) any anticipated impact of the change on the quality or quantity of effluent to be discharged from the POTW.

- 6. All effluent monitoring conducted in accordance with Part II(C)(3) above shall meet the Minimum Quantification Levels (MQL) shown in the table below:

OTHER REQUIREMENTS (continued)

MINIMUM QUANTIFICATION LEVELS (MQLs)

METALS AND CYANIDE			VOLATILE COMPOUNDS			VOLATILE COMPOUNDS		
Pollutant	Required MQL ug/L	EPA Test Method	Pollutant	Required MQL ug/L	EPA Test Method	Pollutant	Required MQL ug/L	EPA Test Method
Antimony (Total) ¹	60	200.7	Benzene ⁴	10	624	1,1,2-Trichloroethane ⁵	10	624
Arsenic (Total) ¹	10	206.2	Bromoform ⁵	10	624	Trichloroethylene ⁵	10	624
Beryllium (Total) ¹	5	200.7	Carbon Tetrachloride ⁵	10	624	Vinyl Chloride ⁵	10	624
Cadmium (Total) ²	1	213.2	Chlorobenzene ⁵	10	624	ACID COMPOUNDS		
Chromium (Total) ¹	10	200.7	Chlorodibromomethane ⁵	10	624	2-Chlorophenol ⁵	10	625
Chromium (3+) ¹	10	200.7	Chloroethane ⁶	50	624	2,4-Dichlorophenol ⁵	10	625
Chromium (6+) ¹	10	200.7	2-Chloroethyl vinyl ether ⁴	10	624	2,4-Dimethylphenol ⁷	10	625
Copper (Total) ²	10	220.2	Chloroform ⁵	10	624	4,6-Dinitro-o-Cresol [2 methyl 4,6-	50	625
Lead (Total) ²	5	239.2	Dichlorobromomethane ⁵	10	624	2,4-Dinitrophenol ⁵	50	625
Mercury (Total) ¹	0.2	245.1	1,1-Dichloroethane ⁶	10	624	2-Nitrophenol ⁶	20	625
Molybdenum (Total) ⁹	30	200.7	1,2-Dichloroethane ⁵	10	624	4-Nitrophenol ⁵	50	625
Nickel (Total) ¹ [Freshwater]	40	200.7	1,1-Dichloroethylene ⁵	10	624	p-Chloro-m-Cresol [4 chloro-3-methylphenol] ⁵	10	625
Nickel (Total) ² [Marine]	5	249.2	1,2-Dichloropropane ⁵	10	624	Pentachlorophenol ⁵	50	625
Selenium (Total) ¹	5	270.2	1,3-Dichloropropylene ⁵	10	624	Phenol ⁵	10	625
Silver (Total) ²	2	272.2	Ethylbenzene ⁵	10	624	2,4,6-Trichlorophenol ⁵	10	625
Thallium (Total) ¹	10	279.2	Methyl Bromide	50	624	BASE/NEUTRAL COMPOUNDS		
Zinc (Total) ¹	20	200.7	Methyl Chloride	50	624	Acenaphthene ⁵	10	625
Cyanide (Total) ¹	10	335.2	Methylene Chloride ⁵	20	624	Acenaphthylene ⁵	10	625
DIOXIN			1,1,2,2-Tetrachloroethane ⁵	10	624	Anthracene ⁵	10	625
2,3,7,8-Tetrachloro-dibenzo-p-dioxin	.00001	1613	Tetrachloroethylene ⁵	10	624	Benzidine ⁴	50	625
VOLATILE COMPOUNDS			Toluene ⁵	10	624	Benzo(a)anthracene ⁵	10	625
Acrolein ⁴	50	624	1,2-trans-Dichloroethylene ⁵	10	624	Benzo(a)pyrene ⁵	10	625
Acrylonitrile ⁴	50	624	1,1,1-Trichloroethane ⁵	10	624	3,4-Benzofluoranthene ⁵	10	625

OTHER REQUIREMENTS (continued)

BASE/NEUTRAL COMPOUNDS			BASE/NEUTRAL COMPOUNDS			PESTICIDES		
Pollutant	Required MQL ug/L	EPA Test Method	Pollutant	Required MQL ug/L	EPA Test Method	Pollutant	Required MQL ug/L	EPA Test Method
Benzo(g,h,i)perylene ⁶	20	625	1,2-Diphenylhydrazine ⁴	20	625	Delta-BHC ⁷	.05	608
Benzo(k)fluoranthene ⁵	10	625	Fluoranthene ⁵	10	625	Chlordane ⁷	.2	608
Bis(2-chloroethoxy)	10	625	Fluorene ⁵	10	625	4,4'-DDT ⁷	.1	608
Bis(2-chloroethyl) ether ⁵	10	625	Hexachlorobenzene ⁵	10	625	4,4'-DDE (p,p-DDX) ⁷	.1	608
Bis(2-chloroisopropyl)	10	625	Hexachlorobutadiene ⁵	10	625	4,4'-DDD (p,p-TDE) ⁷	.1	608
Bis(2-ethylhexyl) phthalate ⁵	10	625	Hexachlorocyclopentadiene ⁵	10	625	Dieldrin ⁷	.1	608
4-Bromophenyl phenyl	10	625	Hexachloroethane ⁶	20	625	Alpha-endosulfan ⁷	.1	608
Butyl benzyl phthalate ⁵	10	625	Indeno (1,2,3-cd) pyrene ⁶ (2,3-o-phenylene	20	625	Beta-endosulfan ⁷	.1	608
2-Chloronaphthalene ⁵	10	625	Isophorone ⁵	10	625	Endosulfan sulfate ⁷	.1	608
4-Chlorophenyl phenyl	10	625	Naphthalene ⁵	10	625	Endrin ⁷	.1	608
Chrysene ⁵	10	625	Nitrobenzene ⁵	10	625	Endrin aldehyde ⁷	.1	608
Dibenz(a,h) anthracene ⁶	20	625	N-nitrosodimethylamine ⁶	50	625	Heptachlor ⁷	.05	608
1,2-Dichlorobenzene ⁵	10	625	N-nitrosodi-n-propylamine ⁶	20	625	Heptachlor epoxide ⁷ (BHC-	.05	608
1,3-Dichlorobenzene ⁵	10	625	N-nitrosodiphenylamine ⁶	20	625	PCB-1242 ⁷	1.0	608
1,4-Dichlorobenzene ⁵	10	625	Phenanthrene ⁵	10	625	PCB-1254	1.0	608
3,3'-Dichlorobenzidine ⁶	50	625	Pyrene ⁵	10	625	PCB-1221	1.0	608
Diethyl Phthalate ⁵	10	625	1,2,4-Trichlorobenzene ⁵	10	625	PCB-1232	1.0	608
Dimethyl Phthalate ⁵	10	625	PESTICIDES			PCB-1248	1.0	608
Di-n-Butyl Phthalate ⁵	10	625	Aldrin ⁷	.05	608	PCB-1260	1.0	608
2,4-Dinitrotoluene ⁵	10	625	Alpha-BHC ⁷	.05	608	PCB-1016	1.0	608
2,6-Dinitrotoluene ⁵	10	625	Beta-BHC ⁷	.05	608	Toxaphene ⁷	5.0	608
Di-n-oetyl Phthalate ⁵	10	625	Gamma-BHC (Lindane) ⁷	.05	608			

¹ Based on Contract Required Detection Level(CRDL) developed pursuant to 40 CFR Part 300.430(b)(8)

² Method 213.2, 239.2, 220.2, 272.2

³ Dioxin National Strategy

⁴ No CRQL/Contract required Quantification Level developed pursuant to 40 CFR Part 300.430(b)(8)) established

⁵ CRQL basis, equivalent to ML

⁶ ML basis, higher than CRQL

⁷ CRQL basis, no ML established

⁸ CRQL basis, higher than ML

⁹ Based on 3.3 times IDL published in 40 CFR 136, Appendix C

OTHER REQUIREMENTS (continued)

MONITORING RESULTS¹ FOR THE ANNUAL PRETREATMENT REPORT

REPORTING YEAR: _____, 200__ TO _____, 200__ NPDES PERMIT NO. _____

TREATMENT PLANT: _____

METALS, CYANIDE and PHENOLS	MAHL, if applicable in ug/l ²	Influent Values in ug/l Dates Sampled				Daily Average Effluent Limit ³	Effluent Dates Sampled			
Antimony (Total)										
Arsenic (Total)										
Beryllium (Total)										
Cadmium (Total)										
Chromium (Total)										
Copper (Total)										
Lead (Total)										
Mercury (Total)										
Molybdenum (Total)										
Nickel (Total)										
Selenium (Total)										
Silver (Total)										
Thallium (Total)										
Zinc (Total)										
Cyanide (Total)										
Phenols (Total)										

¹ It is advised that the influent and effluent samples are collected considering flow detention time through each plant. Analytical MQLs should be used so that the data can also be used for Local Limits assessment and NPDES application purposes.

² Monthly Allowable Headworks Loading limitation in ug/l. Only complete for pollutants that have approved Technically Based Local Limits.

³ Daily average effluent limit in the LPDES permit OR the applicable state Water Quality Standard calculated to an equivalent permit effluent limits. See Appendix B-1, Column (*19).

⁴ Record the names of any pollutants [40 CFR 122, Appendix D, Table II and/or Table V] detected and the quantity in which they were detected.

SIGNIFICANTLY NONCOMPLIANT USERS - ENFORCEMENT ACTIONS TAKEN

[illegible]

PRETREATMENT PROGRAM STATUS REPORT UPDATED SIGNIFICANT INDUSTRIAL USERS LIST

[illegible]

OTHER REQUIREMENTS (continued)

SECTION D. TOXIC SUBSTANCES

The permittee is required to monitor for additional toxic substances due to the designated use of the receiving waterbody as a drinking water supply. The permittee shall analyze the final effluent for the presence of the following toxic substances in accordance with the monitoring requirements listed on Part I page 2 of this permit.

1. A report containing the results of the lab analysis must be submitted to this Office within 20 days of completion of the analysis. **The first analysis shall be performed within six months following the effective date of the permit, and every six months thereafter; or The first analysis shall be performed within the first year following the effective date of the permit, and annually thereafter.**
2. Reports must be submitted to the following address:

Department of Environmental Quality
Office of Environmental Compliance
Post Office Box 4312
Baton Rouge, Louisiana 70821-4312

In addition, enforcement authority has been retained by EPA. Therefore, the original and a copy of the report must also be submitted to the following address until notification that enforcement authority has been assumed by LDEQ:

U.S. Environmental Protection Agency, Region 6
Water Enforcement Branch, 6 EN-WC
1445 Ross Ave.
Dallas, Texas 75202

TOXIC SUBSTANCES (CAS No.)

<u>VOLATILE ORGANIC CHEMICALS</u>	<u>Required</u>	<u>EPA Test</u>
	<u>MDL (ug/l)</u>	<u>Method</u>
acrolein (107-02-8)	50	624
acrylonitrile (107-13-1)	50	624
benzene (71-43-2)	10	624
bromodichloromethane (dichlorobromomethane) (75-27-4)	10	624
bromoform (tribromomethane) (75-25-2)	10	624
carbon tetrachloride (56-23-5)	10	624
chlorobenzene (108-90-7)	10	624
chloroform (trichloromethane)	10	624
chloromethane (methyl chloride) (74-87-3)	50	624

OTHER REQUIREMENTS (continued)

<u>VOLATILE ORGANIC CHEMICALS</u>	<u>Required</u>	<u>EPA Test</u>
	<u>MDL (ug/l)</u>	<u>Method</u>
1,1-dichloroethane (75-34-3)	10	624
1,2-dichloroethane (107-06-2)	10	624
1,1-dichloroethylene (75-35-4)	10	624
dichloromethane (methylene chloride) (75-09-2)	20	624
cis-1,3-dichloropropene	10	624
trans-1,3-dichloropropene	10	624
ethylbenzene (100-41-4)	10	624
para-dichlorobenzene*	---	---
1,1,2,2-tetrachloroethane (79-34-5)	10	624
tetrachloroethylene (127-18-4)	10	624
toluene (108-88-3)	10	624
1,1,1-trichloroethane (71-55-6)	10	624
1,1,2-trichloroethane (79-00-5)	10	624
trichloroethylene (79-01-6)	10	624
vinyl chloride (chloroethylene) (75-01-4)	10	624

ACID EXTRACTABLE ORGANIC CHEMICALS

2-chlorophenol (95-57-8)	10	625
3-chlorophenol	10	625
4-chlorophenol	10	625
2,4-dichlorophenol (120-83-2)	10	625
2,3-dichlorophenol	10	625
2,5-dichlorophenol	10	625
2,6-dichlorophenol	10	625
3,4-dichlorophenol	10	625
2,4-dinitrophenol (51-28-5)	50	625
pentachlorophenol (87-86-5)	50	625
phenol (108-95-2)	10	625
2,4,6-trichlorophenol (88-06-2)	10	625

BASE/NEUTRAL EXTRACTABLE ORGANIC CHEMICALS

anthracene (120-12-7)	10	625
benzidine (92-87-5)	50	625
bis(2-chloroethyl)ether (111-44-4)	10	625
bis(2-chloro-1-methylethyl)ether (39638-32-9)	10	625
bis(2-ethylhexyl)phthalate (117-81-7)	10	625
di-n-butyl phthalate (84-74-3)	10	625
1,3-dichlorobenzene (541-73-1)	10	625
1,2-dichlorobenzene (95-50-1)	10	625
1,4-dichlorobenzene (106-46-7)	10	625
3,3-dichlorobenzidine (91-94-1)	50	625
diethyl phthalate (84-66-2)	10	625
dimethyl phthalate (131-11-3)	10	625
2,4-dinitrotoluene (121-14-2)	10	625

OTHER REQUIREMENTS (continued)

<u>BASE/NEUTRAL EXTRACTABLE</u>	<u>Required</u>	<u>EPA Test</u>
<u>ORGANIC CHEMICALS cont.</u>	<u>MQL (ug/l)</u>	<u>Method</u>
1,2-diphenylhydrazine (122-66-7)	20	625
fluoranthene (206-44-0)	10	625
hexachlorobenzene (118-07-1)	10	625
hexachlorobutadiene (87-68-3)	10	625
hexachlorocyclopentadiene (77-47-4)	10	625
hexachloroethane (67-72-1)	20	625
isophorone (78-59-1)	10	625
nitrobenzene (98-95-3)	10	625
N-nitrosodimethylamine (62-75-9)	50	625
N-nitrosodiphenylamine (86-30-6)	20	625
<u>PESTICIDES & PCB'S</u>		
aldrin (309-00-2)	0.05	608
PCB's (Total)	1.0	608
gamma-BHC (Lindane, Hexachlorocyclohexane) (58-89-9)	0.05	608
chlordane (57-74-9)	0.2	608
4,4"DDD (TDE) (72-54-8)	0.1	608
4,4"DDE (72-55-9)	0.1	608
4,4"DDT (50-29-3)	0.1	608
dieldrin (60-57-1)	0.1	608
endosulfan I (alpha) (115-29-7)	0.1	608
endosulfan II (beta) (115-29-7)	0.1	608
endrin (72-20-8)	0.1	608
heptachlor (76-44-8)	0.05	608
methoxychlor*	---	---
2,3,7,8-tetrachlorodibenzo-p-dioxin (1764-01-6)	**	625
toxaphene (8001-35-2)	5.0	608
2,4-dichlorophenoxyacetic acid (2,4-D) (94-75-7)	10	509B
2-(2,4,5-trichlorophenoxy)propionic acid (2,4,5-TP, Silvex)	4	509B
<u>METALS</u>		
antimony (7440-36-0)	60	200.7
arsenic (7440-38-2)	10	206.2
barium*	---	---
beryllium (7440-41-7)	5	200.7
cadmium (7440-43-9)	1	213.2
chromium III (16065-83-1)	10	200.7
chromium VI (7440-47-3)	10	200.7
copper (7550-50-8)	10	220.2
lead (7439-92-1)	5	239.2

OTHER REQUIREMENTS (continued)

<u>METALS</u>	<u>Required</u> <u>MQL (ug/l)</u>	<u>EPA Test</u> <u>Method</u>
fluoride*	---	---
mercury (7439-97-6)	0.2	245.1
nickel (7440-02-0)	40	200.7
nitrate (as N)*	---	---
selenium (7782-49-2)	5	270.2
silver (7440-22-4)	2	272.2
thallium (7440-28-0)	10	279.2
zinc (7440-66-6)	20	200.7
<u>MISCELLANEOUS</u>		
cyanide	20	335.2
total phenols	5	420.1

* In addition to the effluent lab result for this pollutant, also report MQL and Test Method used.

** Method 625 is a nonquantitative screen that is used to ascertain a positive or negative result. With proper QA/QC techniques, a positive result can be expected at a level above 1 ppm. If this test yields a positive response, then method 613 would be appropriate to establish the quantitative value. Method 613 requires use of the dioxin standard which is dangerous and should not be used unnecessarily.

OTHER REQUIREMENTS (continued)

SECTION D. STORMWATER PROVISIONS

STORMWATER DISCHARGES

- A. This section applies to all stormwater discharges from the facility, either through permitted outfalls or through outfalls which are not listed in the permit or as sheet flow.
- B. Any runoff leaving the developed areas of the facility, other than the permitted outfall(s), exceeding 50 mg/L TOC, 15 mg/L Oil and Grease, or having a pH less than 6.0 or greater than 9.0 standard units shall be a violation of this permit. Any discharge in excess of these limitations, which is attributable to offsite contamination shall not be considered a violation of this permit. A visual inspection of the facility shall be conducted and a report made annually as described in Paragraph 4 below.
- C. The permittee shall prepare, implement, and maintain a Storm Water Pollution Prevention Plan (SWP3) within six (6) months of the effective date of the final permit. The terms and conditions of the SWP3 shall be an enforceable Part of the permit. EPA document 833-R-92-002 (Storm Water Management for Industrial Activities) may be used as a guidance and may be obtained by writing to the U.S. Environmental Protection Agency, Office of Water Resources (RC-4100), 401 M Street, S.W., Washington D.C. 20460 or by calling (202) 260-7786.
- D. The following conditions are applicable to all facilities and shall be included in the SWP3 for the facility.
 - 1. The permittee shall conduct an annual inspection of the facility site to identify areas contributing to the storm water discharge from developed areas of the facility and evaluate whether measures to reduce pollutant loadings identified in the SWP3 are adequate and have been properly implemented in accordance with the terms of the permit or whether additional control measures are needed.
 - 2. The permittee shall develop a site map which includes all areas where stormwater may contact potential pollutants or substances which can cause pollution. Any location where reportable quantities leaks or spills have previously occurred are to be documented in the SWP3. the SWP3 shall contain a description of the potential pollutant sources, including, the type and quantity of material present and what action has been taken to assure stormwater precipitation will not directly contact the substances and result in contaminated runoff.
 - 3. Where experience indicates a reasonable potential for equipment failure (e.g. a tank overflow or leakage), natural condition of (e.g. precipitation), or other circumstances which result in significant amounts of pollutants reaching surface waters, the SWP3 should include a prediction of the direction, rate of flow and total quantity of pollutants which could be discharged from the facility as a result of each condition or circumstance.

OTHER REQUIREMENTS (continued)

4. The permittee shall maintain for a period of three years a record summarizing the results of the inspection and a certification that the facility is in compliance with the SWP3 and the permit, and identifying any incidents of noncompliance. The summary report should contain, at a minimum, the date and time of inspection, name of inspector(s), conditions found, and changes to be made to the SWP3.
5. The summary report and the following certification shall be signed in accordance with LAC 33:IX.2503. The summary report is to be attached to the SWP3 and provided to the Department upon request.

"I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations."

Signatory requirements for the certification may be found in Part III, Section D.10 of this permit.

6. The permittee shall make available to the Department, upon request, a copy of the SWP3 and any supporting documentation.
- E. The following shall be included in the SWP3, if applicable.
1. The permittee shall utilize all reasonable methods to minimize any adverse impact on the drainage system including but not limited to:
 - a) maintaining adequate roads and driveway surfaces;
 - b) removing debris and accumulated solids from the drainage system; and
 - c) cleaning up immediately any spill by sweeping, absorbent pads, or other appropriate methods.
 2. All spilled product and other spilled wastes shall be immediately cleaned up and disposed of according to all applicable regulations, Spill Prevention and Control (SPC) plans or Spill Prevention Control and Countermeasures (SPCC) plans. Use of detergents, emulsifiers, or dispersants to clean up spilled product is prohibited except where necessary to comply with State or Federal safety regulations (i.e., requirement for non-slippery work surface). In all such cases, initial cleanup shall be done by physical removal and

OTHER REQUIREMENTS (continued)

chemical usage shall be minimized.

3. All waste fuel, lubricants, coolants, solvents, or other fluids used in the repair or maintenance of vehicles or equipment shall be recycled or contained for proper disposal. Spills of these materials are to be cleaned up by dry means whenever possible.
4. All equipment, parts, dumpsters, trash bins, petroleum products, chemical solvents, detergents, or other materials exposed to stormwater shall be maintained in a manner which prevents contamination of stormwater by pollutants.
5. All storage tank installations (with a capacity greater than 660 gallons for an individual container, or 1,320 gallons for two or more containers in aggregate within a common storage area) shall be constructed so that a secondary means of containment is provided for the entire contents of the largest tank plus sufficient freeboard to allow for precipitation. Diked areas should be sufficiently impervious to contain spills.
6. All diked areas surrounding storage tanks or stormwater collection basins shall be free of residual oil or other contaminants so as to prevent the accidental discharge of these materials in the event of flooding, dike failure, or improper draining of the diked area. All drains from diked areas shall be equipped with valves which shall be kept in the closed condition except during periods of supervised discharge.
7. All check valves, tanks, drains, or other potential sources of pollutant releases shall be inspected and maintained on a regular basis to assure their proper operation and to prevent the discharge of pollutants.
8. The permittee shall assure compliance with all applicable regulations promulgated under the Louisiana Solid Waste and Resource Recovery Law and the Hazardous Waste Management Law (L.R.S. 30:2151, etc.). Management practices required under above regulations shall be referenced in the SWP3.
9. The permittee shall amend the SWP3 whenever there is a change in the facility or change in the operation of the facility which materially increases the potential for the ancillary activities to result in a discharge of significant amounts of pollutants.
10. If the SWP3 proves to be ineffective in achieving the general objectives of preventing the release of significant amounts of pollutants to water of the state, then the specific objectives and requirements of the SWP3 shall be subject to modification to incorporate revised SWP3 requirements.

OTHER REQUIREMENTS (continued)

F. Facility specific SWP3 Conditions:

1. **Site Map.** The locations of the following areas, where such areas are exposed to precipitation, shall also be included on the site map: grit, screenings and other solids handling, storage or disposal areas; sludge drying beds; dried sludge piles; compost piles; septage and/or hauled waste receiving station; and storage areas for process chemicals, petroleum products, solvents, fertilizers, herbicides and pesticides.
2. **Employee Training.** At a minimum, must address the following areas when applicable to a facility: petroleum product management; process chemical management; spill prevention and controls; fueling procedures; general good housekeeping practices; proper procedures for using fertilizer, herbicides and pesticides.
3. **Potential Pollutant Sources.** The summary of potential pollutant sources must also list the activities and pollutants from the following areas: grit, screenings and other solids handling, storage or disposal areas; sludge drying beds; dried sludge piles; compost piles; septage and/or hauled waste receiving station; and access roads/rail lines.
4. **Description of BMPs to be Used.** In addition to the other BMPs considered, the facility must consider routing storm water into treatment works, or covering exposed materials from the following exposed areas: grit, screenings and other solids handling, storage or disposal areas; sludge drying beds; dried sludge piles; compost piles; septage and/or hauled waste receiving station.
5. **Inspections:** The following areas must be included in all monthly inspections: access roads/rail lines; grit, screenings and other solids handling, storage or disposal areas; sludge drying beds, dried sludge piles; compost piles; septage and/or hauled waste receiving station areas.
6. **Wastewater and Washwater Requirements.** If washwaters are handled in another manner other than the treatment works, the disposal method must be described and all pertinent documentation must be attached to the plan.

OTHER REQUIREMENTS (continued)

SECTION F. WHOLE EFFLUENT TOXICITY REQUIREMENTS (48 HR ACUTE NOEC: FRESHWATER)

1. SCOPE AND METHODOLOGY

- a. The permittee shall test the effluent for toxicity in accordance with the provisions in this section.

REPORTED ON DMR AS OUTFALL: *Daphnia pulex*-TX1Q
Pimephales promelas - TX1Q
 CRITICAL DILUTION: 1.0 %

EFFLUENT DILUTION SERIES: 0.4%, 0.6%, 0.8%, 1.0%, 1.4%

COMPOSITE SAMPLE TYPE: Defined at Section F.3.d.i.

TEST SPECIES/METHODS: LAC 33:IX.4901 (40 CFR Part 136)

Daphnia pulex acute static renewal 48-hour definitive toxicity test using EPA-821-R-02-012, or the latest update thereof. A minimum of five (5) replicates with ten (10) organisms per replicate must be used in the control and in each effluent dilution of this test.

Pimephales promelas (Fathead minnow) acute static renewal 48-hour definitive toxicity test using EPA-821-R-02-012, or the latest update thereof. A minimum of five (5) replicates with ten (10) organisms per replicate must be used in the control and in each effluent dilution of this test.

- b. The NOEC (No Observed Effect Concentration) is defined as the greatest effluent dilution which does not result in lethality that is statistically different from the control (0% effluent) at the 95% confidence level.
- c. This permit may be reopened to require whole effluent toxicity limits, chemical specific effluent limits, additional testing, and/or other appropriate actions to address toxicity.
- d. Test failure is defined as a demonstration of statistically significant sub-lethal or lethal effects to a test species at or below the effluent critical dilution.

2. PERSISTENT LETHALITY

The requirements of this subsection apply only when a toxicity test demonstrates significant lethal effects at the critical dilution. Significant lethal effects are herein defined as a statistically significant difference at the 95% confidence level between the survival of the appropriate test organism in a specified effluent dilution and the control (0% effluent).

OTHER REQUIREMENTS (continued)

a. PART I TESTING FREQUENCY OTHER THAN MONTHLY

- i. The permittee shall conduct a total of two (2) additional tests for any species that demonstrates significant lethal effects at or below the critical dilution. The two additional tests shall be conducted monthly during the next two consecutive months. The permittee shall not substitute either of the two additional tests in lieu of routine toxicity testing, unless the specified testing frequency for the species demonstrating significant lethal effects is monthly. The full report shall be prepared for each test required by this section in accordance with procedures outlined in item 4. of this section and submitted with the period discharge monitoring report (DMR) to the permitting authority for review.
- ii. If one or both of the two additional tests demonstrates significant lethal effects at or below the critical dilution, the permittee shall initiate Toxicity Reduction Evaluation (TRE) requirements as specified in item 5 of this section. The permittee shall notify the Department of Environmental Quality, Office of Environmental Services in writing within 5 days of the failure of any retest, and the TRE initiation date will be the test completion date of the first failed retest. A TRE may be also required due to a demonstration of intermittent lethal effects at or below the critical dilution, or for failure to perform the required retests.
- iii. If one or both of the two additional tests demonstrates significant lethal effects at or below the critical dilution, the permittee shall henceforth increase the frequency of testing for this species to once per quarter for the life of the permit.
- iv. The provisions of item 2.a. are suspended upon submittal of the **TRE Action Plan**.

b. PART I TESTING FREQUENCY OF MONTHLY

If the testing frequency is monthly for a species, the permittee shall initiate the Toxicity Reduction Evaluation (TRE) requirements as specified in item 5 of this section when any two of three consecutive monthly toxicity tests exhibit significant lethal effects at the critical dilution. A TRE may also be required due to a demonstration of intermittent lethal effects at or below the critical dilution, or for failure to perform the required retests.

3. REQUIRED TOXICITY TESTING CONDITIONS

a. Test Acceptance

The permittee shall repeat a test, including the control and all effluent dilutions, if the procedures and quality assurance requirements defined in the test methods or in this permit are not satisfied, including the following additional criteria:

- i. Each toxicity test control (0% effluent) must have a survival equal to or greater than 90%.
- ii. The percent coefficient of variation between replicates shall be 40% or less in the control (0% effluent) for: Daphnia pulex survival test; and Fathead minnow survival test.

OTHER REQUIREMENTS (continued)

iii. The percent coefficient of variation between replicates shall be 40% or less in the critical dilution, unless significant lethal effects are exhibited for: Daphnia pulex survival test; and Fathead minnow survival test.

Test failure may not be construed or reported as invalid due to a coefficient of variation value of greater than 40%. A repeat test shall be conducted within the required reporting period of any test determined to be invalid.

b. Statistical Interpretation

For the Daphnia pulex survival test and the Fathead minnow survival test, the statistical analyses used to determine if there is a statistically significant difference between the control and the critical dilution shall be in accordance with the methods for determining the No Observed Effect Concentration (NOEC) as described in EPA/600/4-90/027F, or the most recent update thereof.

If the conditions of Test Acceptability are met in Item 3.a above and the percent survival of the test organism is equal to or greater than 90% in the critical dilution concentration and all other concentrations, the test shall be considered to be a passing test, and the permittee shall report an NOEC of not less than the critical dilution for the DMR reporting requirements found in Item 4 below.

c. Dilution Water

i. Dilution water used in the toxicity tests will be receiving water collected as close to the point of discharge as possible but unaffected by the discharge. The permittee shall substitute synthetic dilution water of similar pH, hardness and alkalinity to the closest downstream perennial water for;

- A. toxicity tests conducted on effluent discharges to receiving water classified as intermittent streams; and
- B. toxicity tests conducted on effluent discharges where no receiving water is available due to zero flow conditions.

ii. If the receiving water is unsatisfactory as a result of instream toxicity (fails to fulfill the test acceptance criteria of item 3.a.), the permittee may substitute synthetic dilution water for the receiving water in all subsequent tests provided the unacceptable receiving water test met the following stipulations:

- A. a synthetic dilution water control which fulfills the test acceptance requirements of item 3.a. was run concurrently with the receiving water control;
- B. the test indicating receiving water toxicity has been carried out to completion (i.e., 48 hours);

OTHER REQUIREMENTS (continued)

- C. the permittee includes all test results indicating receiving water toxicity with the full report and information required by item 4. below; and
- D. the synthetic dilution water shall have a pH, hardness and alkalinity similar to that of the receiving water or closest downstream perennial water not adversely affected by the discharge, provided the magnitude of these parameters will not cause toxicity in the synthetic dilution water.

d. Samples and Composites

- i. The permittee shall collect two flow-weighted 24-hour composite samples from the outfall(s) listed at item 1.a. above. A 24-hour composite sample consists of a minimum of 4 effluent portions collected at equal time intervals representative of a 24-hour operating day and combined proportional to flow or a sample continuously collected proportional to flow over a 24-hour operating day.
- ii. The permittee shall collect a second 24-hour composite sample for use during the 24-hour renewal of each dilution concentration the for both tests. The permittee must collect the 24-hour composite samples so that the maximum holding time for any effluent sample shall not exceed 36 hours. The permittee must have initiated the toxicity test within 36 hours after the collection of the last portion of the first 24-hour composite sample. Samples shall be chilled to 4 degrees Centigrade during collection, shipping and/or storage.
- iii. The permittee must collect the 24-hour composite samples such that the effluent samples are representative of any periodic episode of chlorination, biocide usage or other potentially toxic substance discharged on an intermittent basis.
- iv. If the flow from the outfall(s) being tested ceases during the collection of effluent samples, the requirements for the minimum number of effluent samples, the minimum number of effluent portions and the sample holding time are waived during that sampling period. However, the permittee must collect an effluent composite sample volume during the period of discharge that is sufficient to complete the required toxicity tests with daily renewal of effluent. When possible, the effluent samples used for the toxicity tests shall be collected on separate days. The effluent composite sample collection duration and the static renewal protocol associated with the abbreviated sample collection must be documented in the full report required in item 4. of this section.
- v. MULTIPLE OUTFALLS. The permittee shall combine the 24-hour composite effluent samples in proportion to the average flow from the outfalls listed in item 1.a. above for the day the sample was collected. The permittee shall perform the toxicity test on the flow-weighted composite of the outfall samples.

4. REPORTING

- a. A valid test must be submitted during each reporting period. The permittee shall prepare a full report of the results of all tests conducted pursuant to this Part in accordance with the Report

OTHER REQUIREMENTS (continued)

Preparation Section of EPA-821-R-02-012, for every valid or invalid toxicity test initiated, whether carried to completion or not. The permittee shall retain each full report pursuant to the provisions of Part III.C. of this permit. For any test which fails, is considered invalid, or which is terminated early for any reason, the full report must be submitted for agency review. The permittee shall submit the first full report to:

Department of Environmental Quality
Office of Environmental Compliance
P. O. Box 4312
Baton Rouge, Louisiana 70821-4312
Attn: Permit Compliance Unit

In addition, enforcement authority has been retained by EPA. Therefore, a copy of the report must also be submitted to the following address:

U. S. Environmental Protection Agency, Region 6
Water Enforcement Branch, 6EN-WC
1445 Ross Ave.
Dallas, Texas 75202

- b. The permittee shall report the following results of each valid toxicity test on the subsequent monthly DMR for that reporting period in accordance with Part III.D. of this permit. Submit retest information clearly marked as such with the following month's DMR. Only results of valid tests are to be reported on the DMR. The permittee shall submit the Table I summary sheet with each valid test.
 - i. Pimephales promelas (Fathead minnow)
 - A. If the No Observed Effect Concentration (NOEC) for survival is less than the critical dilution, enter a "1"; otherwise, enter a "0" for Parameter No. TEM6C.
 - B. Report the NOEC value for survival, Parameter No. TOM6C.
 - C. Report the highest (critical dilution or control) Coefficient of Variation, Parameter No. TQM6C.
 - ii. Daphnia pulex
 - A. If the NOEC for survival is less than the critical dilution, enter a "1"; otherwise, enter a "0" for Parameter No. TEM3D.
 - B. Report the NOEC value for survival, Parameter No. TOM3D.
 - C. Report the highest (critical dilution or control) Coefficient of Variation, Parameter No. TQM3D.

OTHER REQUIREMENTS (continued)

iii. The permittee shall report the following results for all VALID toxicity retests on the DMR for that reporting period.

- A. Retest # 1 (STORET 22415): If the first monthly retest following failure of a routine test for either test species results in an NOEC for survival less than the critical dilution, report a "1"; otherwise, report a "0."
- B. Retest #2 (STORET 22416): If the second monthly retest following failure of a routine test for either test species results in an NOEC for survival less than the critical dilution, report a "1"; otherwise, report a "0."

If, for any reason, a retest cannot be performed during the reporting period in which the triggering routine test failure is experienced, the permittee shall report it on the following reporting period's DMR, and the comments section of both DMRs shall be annotated to that effect. If retesting is not required during a given reporting period, the permittee shall leave these DMR fields blank.

The permittee shall submit the toxicity testing information contained in Table 1 of this permit with the DMR subsequent to each and every toxicity test reporting period. The DMR and the summary table should be sent to the address indicated in 4.a. The permittee is not required to send the first complete report nor summary tables to EPA.

Monitoring Frequency Reduction

- a. The permittee may apply for a testing frequency reduction upon the successful completion of the first four consecutive quarters of testing for one or both test species, with no lethal or sub-lethal effects demonstrated at or below the critical dilution. If granted, the monitoring frequency for that test species (usually the Fathead minnow) and not less than twice per year for the more sensitive test species (usually the *Daphnia pulex*).
- b. CERTIFICATION - The permittee must certify in writing that no test failures have occurred and that all tests meet all test acceptability criteria in item 3.a above. In addition, the permittee must provide a list with each test performed including test initiation date, species, NOECs for lethal and sub-lethal effects and the maximum coefficient of variation for the controls. Upon review and acceptance of the information, the agency will issue a letter of confirmation of the monitoring frequency reduction. A copy of the letter will be forwarded to the agency's Permit Compliance Unit to update the permit reporting requirements.
- c. SURVIVAL FAILURES - If any test fails the survival endpoint at any time during the life of this permit, two monthly retests are required and the monitoring frequency for the affected species shall be increased to once per quarter until the permit is re-issued. Monthly retesting is not required if the permittee is performing a TRE.
- d. This monitoring frequency reduction applies only until the expiration date of this permit, at which time the monitoring frequency for both test species reverts to once per quarter until the permit is re-issued.

OTHER REQUIREMENTS (continued)

5. TOXICITY REDUCTION EVALUATION (TRE)

- a. Within ninety (90) days OF CONFIRMING LETHALITY IN THE RETESTS, the permittee shall submit a **Toxicity Reduction Evaluation (TRE) Action Plan and Schedule** for conducting a TRE. The **TRE Action Plan** shall specify the approach and methodology to be used in performing the TRE. A Toxicity Reduction Evaluation is an investigation intended to determine those actions necessary to achieve compliance with water quality-based effluent limits by reducing an effluent's toxicity to an acceptable level. A TRE is defined as a step-wise process which combines toxicity testing and analyses of the physical and chemical characteristics of a toxic effluent to identify the constituents causing effluent toxicity and/or treatment methods which will reduce the effluent toxicity. The **TRE Action Plan** shall lead to the successful elimination of effluent toxicity at the critical dilution and include the following:
- i. *Specific Activities.* The plan shall detail the specific approach the permittee intends to utilize in conducting the TRE. The approach may include toxicity characterizations, identifications and confirmation activities, source evaluation, treatability studies, or alternative approaches. When the permittee conducts Toxicity Characterization Procedures the permittee shall perform multiple characterizations and follow the procedures specified in the documents "**Methods for Aquatic Toxicity Identification Evaluations: Phase I Toxicity Characterization Procedures**" (EPA-600/6-91/003) and "**Toxicity Identification Evaluation: Characterization of Chronically Toxic Effluents, Phase I**" (EPA-600/6-91/005), or alternate procedures. When the permittee conducts Toxicity Identification Evaluations and Confirmations, the permittee shall perform multiple identifications and follow the methods specified in the documents "**Methods for Aquatic Toxicity Identification Evaluations, Phase II Toxicity Identification Procedures for Samples Exhibiting Acute and Chronic Toxicity**" (EPA/600/R-92/080) and "**Methods for Aquatic Toxicity Identification Evaluations, Phase III Toxicity Confirmation Procedures for Samples Exhibiting Acute and Chronic Toxicity**" (EPA/600/R-92/081), as appropriate;

The documents referenced above may be obtained through the National Technical Information Service (NTIS) by phone at 1-800-553-6847, or by writing:

U.S. Department of Commerce
National Technical Information Service
5285 Port Royal Road
Springfield, Va. 22161

- ii. *Sampling Plan* (e.g., locations, methods, holding times, chain of custody, preservation, etc.). The effluent sample volume collected for all tests shall be adequate to perform the toxicity test, toxicity characterization, identification and confirmation procedures, and conduct chemical specific analyses when a probable toxicant has been identified;

Where the permittee has identified or suspects specific pollutant(s) and/or source(s) of effluent toxicity, the permittee shall conduct, concurrent with toxicity testing, chemical specific analyses for the identified and/or suspected pollutant(s) and/or source(s) of effluent toxicity. Where lethality was demonstrated within 24 hours of test initiation, each 24 hour composite sample

OTHER REQUIREMENTS (continued)

shall be analyzed independently. Otherwise the permittee may substitute a composite sample, comprised of equal portions of the individual 24 hour composite samples, for the chemical specific analysis;

- iii. Quality Assurance Plan (e.g., QA/QC implementation, corrective actions, etc.); and
- iv. Project Organization (e.g., project staff, project manager, consulting services, etc.).
- b. The permittee shall initiate the **TRE Action Plan** within thirty (30) days of plan and schedule submittal. The permittee shall assume all risks for failure to achieve the required toxicity reduction.
- c. The permittee shall submit a quarterly **TRE Activities Report**, with the Discharge Monitoring Report in the months of January, April, July and October, containing information on toxicity reduction evaluation activities including:
 - i. any data and/or substantiating documentation which identifies the pollutant(s) and/or source(s) of effluent toxicity;
 - ii. any studies/evaluations and results on the treatability of the facility's effluent toxicity; and
 - iii. any data which identifies effluent toxicity control mechanisms that will reduce effluent toxicity to the level necessary to meet no significant lethality at the critical dilution.

The **TRE Activities Report** shall be submitted to the following addresses:

Department of Environmental Quality
Office of Environmental Compliance
P.O. Box 4312
Baton Rouge, Louisiana 70821-4312
Attn: Permit Compliance Unit

U.S. Environmental Protection Agency, Region 6
Water Enforcement Branch
1445 Ross Avenue
Dallas, Texas 75202

- d. The permittee shall submit a Final Report on Toxicity Reduction Evaluation Activities no later than twenty-eight (28) months from confirming lethality in the retests, which provides information pertaining to the specific control mechanism selected that will, when implemented, result in reduction of effluent toxicity to no significant lethality at the critical dilution. The report will also provide a specific corrective action schedule for implementing the selected control mechanism.

A copy of the Final Report on Toxicity Reduction Evaluation Activities shall also be submitted to the above addresses.

OTHER REQUIREMENTS (continued)

- e. Quarterly testing during the TRE is a minimum monitoring requirement. EPA recommends that permittees required to perform a TRE not rely on quarterly testing alone to ensure success in the TRE, and that additional screening test be performed to capture toxic samples for identification of toxicants. Failure to identify the specific chemical compound causing toxicity test failure will normally result in a permit limit for whole effluent toxicity limits per federal regulations at 40 CFR 122.44(d)(i)(v).